

FLOOR SLIP RESISTANCE TESTING CERTIFICATE

Testing Certificate Ref No:

AW/FS/2009010



Client	Granite Setts UK
Location	++Samples++
Date Tested	01 October 2020
Pendulum Equipment Used	KSS Pendulum
Pendulum Serial No	ST13
Pendulum Calibrated	20th November 2019
Slider Type Used (Delete as Required)	96 slider
Slider Ser No(s) - Batch	96#72
Slider Date Expiry	15 th December 2020

The Pendulum was used in accordance with the United Kingdom Slip Resistance Group (UKSRG) guidelines for testing floors to ascertain the slip resistance to BS EN 14231. The tests were carried out under: -

- Wet Conditions (Using potable water to cover the whole test area and refreshed between tests).
- Dry & sunny conditions

Eight measurements were taken at each condition and in three different horizontal planes (0, 45 and 90 degrees) at each position. The first three measurements were discarded to allow checks for slider stabilisation. The median (average) of the remaining results were then calculated, as advocated by the UKSRG/Health & Safety Executive (HSE). The results for the floors tested are indicated in the table below:

The HSE / UKSRG has determined a minimum Pendulum Test Value reading of 36 must be obtained in all conditions (Dry, Wet, or Contaminated) and on a level surface for a floor to pass the test

Ref	Area/Room	Surface	Ambient Temp (deg C)	Mean (Average) Reading	Pass / Fail
1	Sample	Granite	18c	DRY 62	
		Sawn		WET 42	PASS
				R Rating	11
2	Sample	Granite	18c	DRY 76	
		Finished		WET 53	PASS
				R Rating	12

Signed on behalf
of FloorSlip Ltd:

A.I. Wylie

Name:

Andrew Wylie

Date:

01/10/20

Valid Until
Date:

N/A

This test certificate is not valid or original if the embossed company stamp is not present

FloorSlip Ltd - www.floorslip.co.uk
e:mail - info@floorslip.co.uk
Tel: 08719 152535 / 08713 155789

Registered Office - The Meridien, 4 Copthall House, Coventry, CV1 2FL Company number: 07757686
Please do NOT reply to this address as it is an unmonitored Address

